



NOTES:

1. INSTALLATIONS BY UTILITY CONTRACTORS REQUIRE A SEWER PERMIT AND ARE INSPECTED BY AN LCWSA INSPECTOR. DO NOT BACKFILL PRIOR TO INSPECTION.
2. A BACKFLOW PREVENTION VALVE IS RECOMMENDED AND CAN BE INSTALLED INSIDE OR OUTSIDE.
3. MINIMUM COVER OF SANITARY SEWER LATERAL SHALL BE 4' BELOW FINISHED GRADE
4. ALL CONNECTIONS SHALL BE GASKETED TYPE. NO GLUED CONNECTIONS OR FLEXIBLE COUPLING SHALL BE USED.
5. CONNECTIONS TO EXISTING SEWER MAIN SHALL BE PVC GASKETED TYPE WYE CONNECTION SADDLES.

NOT TO SCALE

LIVINGSTON COUNTY WATER AND SEWER AUTHORITY		
TYPICAL SANITARY SEWER LATERAL MAIN SIDE DETAIL		
ISSUED	JUNE 1998	S-01
REVISED	DECEMBER 2022	