



NOTES:

1. MANHOLES 18' & DEEPER SHALL BE 5' DIAMETER.
2. MANHOLE TOP SLABS, FRAMES AND COVERS SHALL BE DESIGNED FOR USE UNDER H-20 LOADING
3. REQUIRE 24" I.D. FRAME AND COVER, NEENAH R-1713, OR APPROVED EQUAL.

LIVINGSTON COUNTY WATER AND SEWER AUTHORITY	
TYPICAL SANITARY SEWER MANHOLE DETAIL <i>NOT TO SCALE</i>	
ISSUED	FEBRUARY 1997
REVISED	DECEMBER 2022
S-02	