



**NOTES:**

1. WATER SERVICE PIPE IS TO HAVE MINIMUM COVER DEPTH OF 5 FEET FROM FINISHED SURFACE.
2. WATER SERVICE TAP IS TO BE MADE ON CUSTOMER SIDE OF WATER MAIN PIPE. FOR PLASTIC AND CAST/DUCTILE IRON WATER MAIN PIPE USE DOUBLE STRAP BRASS TAPPING SADDLE.
3. WATER SERVICE PIPE IS TO RUN PERPENDICULAR TO WATER MAIN PIPE.
4. FOR WATER SERVICE PIPE 1½ INCHES AND LARGER, ADD CURB BOX ARCH TO CURB BOX.
5. TRACER WIRE MUST BE INSTALLED FOR PLASTIC WATER SERVICE PIPE.
6. WARNING TAPE MUST BE INSTALLED WITH ALL OPEN CUT TRENCHED WATER SERVICE PIPE INSTALLATIONS.
7. NO CURB BOXES SHALL BE LOCATED IN DRAINAGE SWALES OR DITCHES.

LIVINGSTON COUNTY WATER AND SEWER AUTHORITY		
<b>NEW WATER SERVICE DETAIL</b>		
ISSUED	JUNE 1998	W-01
REVISED	MAY 2025	