



NOTES:

1. DOUBLE STRAP BRASS SERVICE SADDLES SHALL BE USED ON ALL TAPS.
2. STAINLESS STEEL INSERTS SHALL BE USED AT ALL PE CONNECTIONS.

| | | |
|---|---------------|------|
| LIVINGSTON COUNTY WATER AND SEWER AUTHORITY | | |
| MANUAL AIR RELEASE | | |
| NOT TO SCALE | | |
| ISSUED | JUNE 1998 | W-03 |
| REVISED | FEBRUARY 2026 | |