




SITUATION	SCHEMATIC	REQUIREMENTS
<p>I</p> <p>WATER MAIN ABOVE SEWER MAIN</p>		
<p>II</p> <p>WATER MAIN ABOVE SEWER MAIN</p>		<p>A. WATER MAIN AND SEWER MAIN SHALL BE ONE FULL LENGTH CENTERED AT CROSSING (10' MINIMUM) SO THAT BOTH JOINTS WILL BE AS FAR FROM THE SEWER AS POSSIBLE.</p> <p>B. WHEN BOTH WATER MAIN AND SEWER MAIN ARE NEW, SLEEVE SEWER LINE WITH STEEL CASING FOR FULL LENGTH OF PIPE AT CROSSING OR WHEN ONE LINE IS EXISTING, SLEEVE PIPE BEING INSTALLED WITH STEEL CASING FOR ONE FULL LENGTH OF PIPE.</p>
<p>III</p> <p>SEWER MAIN ABOVE WATER MAIN</p>		<p>A. WATER MAIN AND SEWER MAIN SHALL BE ONE FULL LENGTH CENTERED AT CROSSING (10' MINIMUM) SO THAT BOTH JOINTS WILL BE AS FAR FROM THE SEWER AS POSSIBLE.</p> <p>B. SLEEVE SEWER MAIN WITH STEEL CASING FOR ENTIRE LENGTH OF PIPE (EACH SIDE OF CROSSING).</p> <p>C. PROVIDE CRADLE OF CONCRETE OR CRUSHER RUN STONE FOR WATER MAIN AND SEWER MAIN FOR ENTIRE LENGTH OF PIPE EACH SIDE OF CROSSING.</p>

LIVINGSTON COUNTY WATER AND SEWER AUTHORITY	
SEWER / WATER MAIN CROSSING DETAIL	
NOT TO SCALE	
ISSUED	JUNE 1998
REVISED	MARCH 2025
W-08	