LIVINGSTON COUNTY
WSA
WATER & SEWER AUTHORITY

Executive Director
Jason Molino

Deputy Director
Lauren Monaghan

ADDENDUM NO. 1

Livingston County Water and Sewer Authority
2027 Water and Sewer Construction & Maintenance Materials Bid

Date: November 16, 2026

REVISIONS TO THE BID SPECIFICAIONS:

1. Within the Water Meter Pit Including Cover Bid Specifications under section B. Manufacturers Add ”3. Ford; or approved equal”

CLARIFICATIONS:

1. Residential water service dual check valves to be Meter Swivel x MNPT Union or Female x Female iron pipe thread.
2. Additional manufacturers have been included for Meter Pits including Mueller, AY McDonald, Ford or other approved equal are acceptable.
3. Meter pits shall be (15” and 18” Diameter) with touch read cover and insulated pad.
4. The 1” x ¾ reducers are to be no-lead brass threaded reducers for residential water meters.
5. Curb boxes to be 1” diameter, 5’ bury with two-hole lid and 29” -35” rods.
6. Standard watermain valve box to be 2-piece screw type with lid.
7. All tapping saddles to be double strap brass (no stainless-steel straps).
8. All materials can be imported or domestic.

END OF ADDENDUM NO. 1